

18 November 2011

Mr. David Nahigian  
Branch Chief, Facilities and Administration  
The State of California, Office of Technology Services  
3101 Gold Camp Drive  
Rancho Cordova, CA 95670  
USA

Re: Tier III Certification of Design Documents of the State of California, Office of Technology Services - Gold Camp Data Center

Dear Mr. Nahigian,

The Uptime Institute is pleased to announce the Tier Certification of Design Documents of the State of California, Office of Technology Services - Gold Camp Data Center, as fulfilling Tier III Concurrently Maintainable data center criteria. This Certification is based upon capacities listed within the design documentation submitted from 22 September 2010 to 18 November 2011.

This Certification recognizes the Gold Camp Data Center design as supporting any planned work on the site infrastructure without disrupting operations. The demand is limited by the data center's engine-generator capacity of 3,675 kW.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I hereto and incorporated herein.

Congratulations on this achievement.

Sincerely,



Vincent Renaud  
Managing Principal and Tier Certification Authority